

SAL National Pty Ltd ABN 21 633 189 474 40 Biloela Street Villawood NSW 2163 P +61 2 9723 3099 F +61 2 9724 1899 sales@sal.net.au www.sal.net.au

## **DECLARATION OF CONFORMITY**

SAL NATIONAL PTY LTD of 40 Biloela Street, Villawood NSW 2163, ABN: 21 633 189 474, <a href="https://www.sal.net.au">www.sal.net.au</a> declare under our sole responsibility that the products identified and sold by SAL NATIONAL PTY LTD as:

## Models No.

SL9726/20TC, SL9726/20TC/DP, SL9726/20TC/HP, SL9726/20TC/EM SL9726/40TC, SL9726/40TC/DP, SL9726/40TC/HP, SL9726/40TC/EM SL9726/50TC/DP, SL9726/50TC/EM

are in conformity with the Australian / NZ Standards as nominated, for which a representative sample has been examined/tested and found to be in conformity with the requirements of the following Standards;

1. AS/NZS 60598.1

- Luminaires General requirements and tests.

2. AS/NZS 60598.2.1

- Fixed general-purpose luminaires.

3. AS/NZS 60598.2.22

- Luminaires Particular requirements – luminaires for emergency lighting.

4. AS/NZS CISPR 15

- Limits and methods of measurement of radio disturbance characteristics of electrical light and similar equipment.

5. AS/NZS 2293.3: 2018

Emergency lighting and exit signs for buildings
Part 3: Emergency Luminaires and exit signs
SL9726/20TC/EM, SL9726/40TC/EM, SL9726/50TC/EM
Test Report Form No. - WPL-22933A-01A

Signature: M Farmer Authorised signatory: Mr Michael Farmer

Position: SAL General Manager Marketing

Declaration #: 20240110-01 Date: 10 January 2024

Office use: SAL - Signatory, QA & Compliance

